



कार्यालय : जिला दण्डाधिकारी-सह-उपायुक्त, पलामू।
(जिला योजना शाखा)

e-mail: dpopalamau@gmail.com

Office: 06562-230859

शुद्धि-पत्र

Advertisement PR NO. 249565 द्वारा प्रकाशित जेनसेट के विज्ञापन के Specification एवं तिथि में निम्न रूप से आंशिक संशोधन किया जाता है :-

1. Specification :-

Sl. No.	Particulars	Specifications
1	Engine	6 cylinders, in line 4 stroke, radiator cooled engine
		Full Authority Electronic engine
		Well-designed air handling system :Dry Type, replaceable paper element air cleaner with restrictions indicator, Air to Air aftercooling
		Fuel economy : Dual filter system pre filter including water separator and water in fuel (WIF) sensor and main filter
		Electrical lift pump for faster response
2	Alternators	2 x 12 V DC batteries
		Brushless type, screen protected, revolving field, self excited alternator
		3 phase reconnectable Winding with 12 terminals brought out for connections
3	Control Panel	Best in class efficacy
		Aluminium bus bars with suitable capacity with incoming/outgoing terminals
		Indication Lamps for "LOAD ON" and "Set Running"
4	Power Command	MCCB of suitable rating with overload and short circuits protections
		Operative Interface includes LED Backlit LCD display
		Engine metering : Oil Pressure, Coolant temperature, Battery voltage and Engine Speed
		Remote Start and Stop
5	Silencer	12-and 24-Volt DC operations
		Sleep Mode
6	Certifications	Hospital grade silencer suitability optimized to meet stringent noise emission standards laid down by MoEF/CPCB
7	Acoustic Enclosure	Specification conform to ISO 8528 standards
		Specially designed to meet stringent MoEF/CPCB norms of 75 dBA@1 mtr at 75% load under free field conditions
		High quality noise absorbent and fire retardant
		Fluid drains for lube oil and fuel
		Fuel filling arrangements inside the enclosures

2. बीड में 250 KVA जेनसेट की दर अलावे Specification सहित 200 KVA एवं 160 KVA का दर भी निविदा दाता समर्पित करेंगे।

3. RFP जमा करने की अंतिम तिथि 23.07.2021 को 1:00 बजे अपराह्न।

4. RFP खोलने की तिथि 23.07.2021 को 1:30 बजे अपराह्न निर्धारित की गई है।

शेष शर्तें यथावत रहेंगे।

ए०/-

उपायुक्त, पलामू।

ज्ञापांक 570 / जियोदिनांक 19/07/2021

प्रतिलिपि :- जिला जनसम्पर्क पदाधिकारी, पलामू को सूचनार्थ प्रेषित। निदेश है कि उक्त शुद्धि-पत्र का प्रमुख सामाचार पत्रों में प्रकाशित करना सुनिश्चित करेंगे।

प्रतिलिपि :- जिला सूचना विज्ञान पदाधिकारी, पलामू को सूचनार्थ प्रेषित। निदेश है कि उक्त शुद्धि-पत्र को पलामू जिला के अधिकारिक वेबसाईट पर अपलोड कराना सुनिश्चित करेंगे।

उपायुक्त, पलामू।