

विद्युत कार्यशाला कुनैरा इटावा

दिनांक. 22.09.2020 को जनपद इटावा में क्षतिग्रस्त परिवर्तक के सापेक्ष बदले गये परिवर्तकों का क्षमता सहित) विवरण

क्र.स.	तहसील का नाम	11 केवीए फीडर का नाम	बदले गये परिवर्तक के स्थल का पता	परिवर्तक की क्षमता केवीए	खण्ड
1	Bharthana	Sujipura	PTW Madhusudan Bibouli	25	EDD-2
2	Bharthana	Sujipura	Nagla Mahipat	10	EDD-2
3	Etawah	Udi	Sunwara	16	EDD-2
4	Etawah	Udi	Pul Ki Madaiya	16	EDD-2
5	Bharthana	Bhaisai	Thari	10	EDD-2
6	Bharthana	Kushna	Nagla Ajab	10	EDD-2
7	C. Nagar	Bithouli	PTW Bal Vir Singh Katrauli	25	EDD-2
8	C. Nagar	Bithouli	PTW Anant Ram Birouri	25	EDD-2
9	C. Nagar	Hanumantpura	PTW Uma Singh Piprouli Gadhiya	25	EDD-2
10	C. Nagar	Hanumantpura	PTW Ram Sewak Piprouli Gadhiya	25	EDD-2
11	C. Nagar	Bhareh	PTW Pan Singh Harpura	25	EDD-2
12	Etawah	Pachaygaon	PTW Ram Rati Yadav Sikandarpur	25	EDD-2
13	Etawah	Gaurapura	Daulatpur	100	EDD-2
14	Bharthana	Mahewa	PTW Hari Yogindera Lalpura	25	EDD-2
15	Etawah	Manikpur Bishu	Bhoosa	63	EDD-2
16	Saifai	Havera	Chhimara	63	EDD-3
17	Jaswant Nagar	Fatehpura	PTW Bachhi Lal Yadav Nagla Datti	100	EDD-3
18	Jaswant Nagar	Raja Ka Bag	Child /Bachcha Jail	25	EDD-3
19	Jaswant Nagar	Fatehpura	Nagla Kesho	25	EDD-3
20	Saifai	Parasana	Manikpur	16	EDD-3
21	Saifai	Parasana	Timaruya Chauraha	63	EDD-3
22	Saifai	Saifai-2	Baghuyia	16	EDD-3
23	Takha	Choubiya	PTW Ram Sewak Goradayalpur	25	EDD-3
24	Takha	Choubiya	PTW Mahesh Chand Choubiya	25	EDD-3

SUMMARY

Ser No	TF Cap in KVA	Divisions			Total
		EDD-1	EDD-2	EDD-3	
1	10	0	3	0	3
2	16	0	2	2	4
3	25	0	8	4	12
4	63	0	1	2	3
5	100	0	1	1	2
6	160	0	0	0	0
7	250	0	0	0	0
8	400	0	0	0	0
Total		0	15	9	24