

GOVERNMENT OF PUDUCHERRY
OFFICE OF THE DEPUTY DIRECTOR
GOVERNMENT GENERAL HOSPITAL,

--:o0o:--

Enquiry No.2/GHY/B2/Bills/AMC/ 2018-19/ 919

Yanam, dt.12/04/2019

SHORT TENDER NOTICE

Sub:- G.H. Yanam – Calling for quotation – Regarding.

--:o0o:--

Sealed quotations for hiring of 100 KVA Diesel Generator Set are hereby , invited to keep in Government General Hospital, Yanam, immediately due to emergency, super scribed on cover as "Quotation for Hiring of 100 KVA Generator" Due date is 16/04/2019 so as to reach this office on or before 4.00 p.m and intimate your acceptance of the following conditions in case an order is placed with you.


Sl.No	Name of the Work/AMC	Quantity (in nos.)
1.	Hiring of 100 KV Generator	Each one

We understand that the Govt. General Hospital, Yanam reserves the right to accept or reject all the quotations or either of the options without assigning any reasons thereof.

The above charges are inclusive of :

- All applicable taxes including service tax.
- Insurance cover of machine.
- Cost of lube oil.
- Comprehensive maintenance of generator.
- Diesel Generator set installation Charges.
- Charges for providing suitable Diesel Generator set bed, if required

The diesel shall be supplied by the undersigned.


12/4/2019
DEPUTY DIRECTOR
GOVT. GENERAL HOSPITAL
YANAM -533464

To

- All the Departments in Yanam Region – For display in their notice boards.
- The Regional Administrator, Yanam – "For Publishing content in Yanam Website"

Copy submitted to: The Director, Dte. Of Health and Family Welfare Services,
Puducherry.

GENERAL TERMS AND CONDITIONS FOR DG SET HIRING

1. Operating time of Diesel Generator set shall be 24 hours is required, shall be provided by the Contractor including on Sundays and holidays.
2. Operation also includes topping of fuel ,changeover ,operations etc., Wherever Auto Main Failure(AMF) is provided, the contractor to monitor on regular basis, the fuel level, topping if required and provide a operator in case of AMF failure. No additional charges will be paid for the same.
3. No additional rent or operator charges will be paid for operation on any holidays and weekends, if required.
4. The contractor shall be responsible for proper maintenance of Registers, log books etc., as required under the applicable laws/Statutory provisions and or Rules/Regulations framed there under.
5. The contractor shall bear all the costs and expenses in respect of all charges, including stamp duty etc., for agreement and /or any other documents/agreements ,which are required to be executed.
6. All necessary tools like clamp meter, drilling machines and pliers and other essential tools for effective maintenance of the Diesel generator equipments shall be provided by the contractor.
7. Contractor shall arrange for comprehensive maintenance of their Diesel Generators set as prescribed by the supplier for reducing the breakdowns to the minimum and for uninterrupted operation of Diesel generator Set.
8. All the maintenance expenses including replacement of spares for the Diesel Generator set along with Periodic replacement of lube oil shall be borne by the contractor.
9. The Contractor/owner of the Diesel Generator set has to arrange at their own cost all necessary approval from Government or any other statutory body including environmental clearance, if required for installation and running of Diesel Generator set at respective sites.
10. The diesel will be supplied to them on an actual basis.
11. Owner/Contractor of the Diesel Generator set has to bear the installation/transportation charges of Diesel/generator set.
12. Owner/Contractor of the Diesel Generator set has to maintain a log book at the site to record the following:
 - i) Hour meter reading
 - ii) Time for which the generator was operational (Generator off and on timings)
 - iii) No. of Units generated through DG Set
 - iv) Consumption of Diesel
 - v) Signature of the Official concerned. The log book shall be submitted to the officer-in-charge as and when called upon by the Officer-in-charge.


13. The generator downtime shall be kept to all care shall be taken so that the downtime of the DG set is kept minimum. During the currency of the contract, Maximum permissible frequency of failures in a month a) Once for approximately one hour b) Four times for approximately half hour.

14. In case of major breakdowns; standby arrangement shall be made within 24 hours from the time of breakdown. In case of Poor performance/Non performance of DG set taken on hire, the penalty (twice hiring charges) per day may be deducted from the hiring charges for the month. 20.5% of annual contract value shall be kept as retention money (Performance Guarantee) during the contract period, which will be forfeited in case of poor performance or non performance. Any of the deliverables not being delivered for more than 2 days in a quarter would mean "poor performance".

15. Self start Battery condition shall be well maintained for trouble free operation.

16. As per the prevailing guidelines of the state/Central Govt. (e.g., Pollution control board, Electrical Inspector and power distribution company etc.) the permission for installations of DG sets should be obtained.

17. The statutory fees shall be paid by the Bank but the arrangement and liaisoning with the concerned Govt. Departments shall be under the scope of the contractor. Wherever applicable, the Electricity tax for Generation of Energy based on the number of units generated, should be paid to the concerned Energy Dept.,/Electrical Inspectorate, Electrical safety Dept.,


12/4/2019
DEPUTY DIRECTOR
GOVT. GENERAL HOSPITAL
YANAM