

NIC

LCE No. 04/EDK/EE/AEE/(C&B)/F.21/2019-2020/ 84  
GOVERNMENT OF PUDUCHERRY  
ELECTRICITY DEPARTMENT

\*\*\*\*\*

ENQUIRY NOTICE

Karaikal, Dt: 5/11/2019

Sub:- E.D.K - Electricity Department - Enquiry for the manufacturing of 7.32 mts. long (24') R.C.C Poles at the department pole casting yard, surakudy - Reg.

Please send your lowest quotation for manufacturing and supplying of the R.C.C. pole of 7.32 mts (24') long in a sealed cover super scribed with enquiry number and date, so as to reach this office on or before 15.00 hrs of 19 / 11 /2019 and intimate your acceptance of the following conditions if an order is placed with you. The tender will be opened on 19 / 11 /2019 at 16.00 Hrs.

Sl. No.	Description of Work	Approximate Qty.	Rate/ Unit	Amount
1	Manufacturing of 7.32 Mtrs. long R.C.C Pole in the Department pole casting yard, including supply of all materials required for the work such as 12mm RTS rod, 6mm MS rod, Cement (43 grade OPC), 20 mm blue metal, river sand, etc., GST (a) SGST as applicable (b) CGST as applicable	85 Nos.		

**RATE:**

The rate should be quoted for finished product including the cost of materials to be issued by the tenderer. The rate shall be inclusive of labour charges for welding of grills and casting, lifting & stocking of poles from curing tank to storage yard. The Quantity may subject to variation of  $\pm 10\%$  of total quantity.

**1. TECHNICAL SPECIFICATIONS:-**

The 7.32 mt (24') long RCC poles of size 22.90 x 15.20 cm at the bottom and 14.70 x 11.80 cm at the top in widths and breadths in cement concrete 1:1½:3 (one cement, one and half sand and three 20mm Hand broken granite metal) using the reinforcement prepared with 4 Nos. of 12mm diameter twisted deformed bars/thermo mechanically treated bars as main rod (without joint/lap) throughout and 6mm mild steel rods as stirrups at 15cms centre to centre and to be tag welded with main rods.

(i) The materials proposed to be used for one pole:

- a. Cement : Not less than 75 Kg
- b. 12mm TMT rod : Not less than 27 Kg
- c. 6mm MS rod : Not less than 6 Kg
- d. Welding rod No.8 : 6 Nos.
- e. 20mm HBG metal : 0.19 Cu. Mt

(ii) Conditions for manufacturing of RCC poles:

- a. The manufacturing of the poles is to be carried out at the Department pole casting yard at surakudy.
- b. The cement should confirm to ISS 269/1989.
- c. The steel such as 6mm MS rod, 12mm TMT rod should confirm to IS 1786/1985.
- d. No joints to be tapped in steel fabrication.
- e. Rings to be made in 6mm MS rod at 15cm centre to centre end should be tack welded with main rods.
- f. Only salt free river sand to be used for RCC works.
- g. Quality water to be used shall be tested in advance and found acceptable.
- h. The reinforcement should be laid as per drawing.
- i. Necessary test certificate to the TMT rod/steel should be obtained from the Government authorized testing labs.
- j. The grills fabricated will be inspected by the Engineer in charge for the work and only after approval of the same, the grills are to be used for pole casting works.

f. A tube test on the cement concrete will be done on the date of inspection by the Engineer of this department to ascertain proper using of mix in casting work.

g. Please state whether you have registered in Industries department PIPDIC for the above work. If so please furnish the details of work done so for.

h. Tenderer should clearly mention whether there will be any deviation from the design of this department while manufacturing the R.C.C. Poles.

i. The Tenderer should be registered with PWD/CPWD, Puducherry.

8. The tenderer who wish to be present for the opening of the tender may call at the office of the Executive Engineer, Electricity Department, Karaikal at the prescribed time either in person or may send their representative duly accredited to this effect.

9. The tenderer whether his tender accepted or not shall treat details of the tender specification and other documents attached as private and confidential.

10. The Executive Engineer reserve the right:-

a. To reject any or all tender without assigning any reasons therefore and.

b. To award contract to one of more contractors for the some items covered by this specification.

11. JURISDICTION:

No suit or any proceeding in regard to any matter arising in any respect under this contract shall be institute in any court say in the city civil court of Puducherry, Karaikal as the court on small cases at Karaikal, Puducherry. It is agreed no other court shall have jurisdiction to entertain any suite or proceeding at even though part of the cause of action might within the jurisdiction. If any court of Puducherry and not in the court in Chennai city then it is agreed to between the parties that such suites are proceeding shall not be instituted in a court within union territory of Puducherry state and no other court outside Puducherry state have jurisdiction even though any part the cause of action might arise within the jurisdiction of such courts.

Yours faithfully

*J. S. Sathya*  
24/11/19.

9/12  
ASSISTANT EXECUTIVE ENGINEER/C&B  
ELECTRICITY DEPARTMENT  
KARAIKAL.

To, *The District Information Officer,*

The NIC Website,

Karaikal.

*--- with a request to display this notice  
in NIC website*